

CERTIFICATE OF COMPLIANCE

Certificate Number 20161109-E485789
Report Reference E485789-20160923
Issue Date 2016-NOVEMBER-09

Issued to: T & T SISTEMI SRL
Via Leo Valiani, 67/77
52025 Levane - Bucine Arezzo ITALY

**This is to certify that
representative samples of**

**INDUSTRIAL CONTROL PANELS RELATING TO
HAZARDOUS LOCATIONS**

Industrial control panels relating to hazardous locations with intrinsically safe circuit extensions for Class I, Groups A, B, C and D, Class II, Groups E, F and G and Class III Hazardous Locations, when connected in accordance with appropriate control drawing.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 698A Industrial Control Panels Relating to Hazardous (Classified) Locations
Standard No. CAN/CSA C22.2 No. 157-92, Reaffirmed 2012, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

